

## STANDARD INFORMATION

**If your product is certified to UL 217, then it needs to be recertified to UL 217 10<sup>th</sup> Ed. / ULC 531 5<sup>th</sup> Ed.**

**This SUN applies to all products certified to UL 217.**

**Superseded Standard:**

Smoke Alarms [UL 217]

**Replacement Standard:**

Smoke Alarms [UL 217:2024 Ed.10]

Standard for Smoke Alarms [CAN/ULC 531:2024 Ed.5]

## EFFECTIVE DATE OF NEW/REVISED REQUIREMENTS

**Effective Date: November 17, 2027**

## IMPACT, OVERVIEW, AND ACTION REQUIRED

**Impact Statement:** UL 217 10<sup>th</sup> Ed. / ULC 531 5<sup>th</sup> Ed. has been issued. All reports currently certified to UL 217 need to be evaluated and certified to UL 217 10<sup>th</sup> Ed. / ULC 531 5<sup>th</sup> Ed prior to the effective date. Due to the changes between standards, a full evaluation to UL 217 10<sup>th</sup> Ed. / ULC 531 5<sup>th</sup> Ed is required.

Note: The 10<sup>th</sup> edition of UL 217 is harmonized with the 5<sup>th</sup> edition of ULC 531.

Note: If the listing references a Canadian standard, per the Canadian Electrical Code (CSA C22.2#0) Section titled Language of markings, Caution and Warning Markings shall be in English and French.

***Current Listings Not Active? – Please immediately identify any current Listing Reports or products that are no longer active and should be removed from our records. We will do this at no charge as long as Intertek is notified in writing prior to the review of your reports.***